

From: [Neil Mulvey](#)
To: [Wallace, Leonard](#)
Cc: [Swift, Joe](#); [Hicks, Rob](#); [Sirois, Mike](#)
Subject: Crystal Ice - Follow-up
Date: Thursday, June 28, 2012 12:05:08 PM
Attachments: [MA State Code - Safety Code for Mech Refrigeration.pdf](#)
[ATT16253.htm](#)

Mr. Wallace,

I wanted to provide you a quick update on our progress in addressing the issues you have identified regarding the relief vent / exhaust discharge locations at the Crystal Ice facility in New Bedford, MA.

American Refrigeration Company (Crystal Ice's refrigeration contractor) has confirmed that the existing system was designed/installed in accordance with the Code of Massachusetts Regulations 522 CMR 9.00 Refrigeration & Air Conditioning. Section 9.90 of that Code includes a "[Safety Code for Mechanical Refrigeration](#)." Paragraph 9.90 (1)(a) states that **"In accordance with the provisions of M.G.L. c. 146, §2, the Board of Boiler Rules herewith adopts by reference the 1997 ANSI/ASHRAE Safety Code. The application of this Code is intended to assure that safe design, construction, installation, operation, and inspection of every refrigeration system employing a fluid which normally is vaporized and liquified in its refrigeration cycle."**

A copy of the above referenced Code is attached for your information.

We are presently evaluating the areas of concern against the ANSI/ASHRAE Safety Code and will provide a report for your consideration by COB July 6.

Thank you.